# Utah Department of Environmental Quality Division of Drinking Water

# **Public Water System Inventory Report**

Run Date: 08/04/2011 12:11 pm

PWS ID: UTAH14024 Name: MATERION NATURAL RESOURCES

Legal Contact MATERION NATURAL RESOURCES Rating: Approved

JEFFREY MASON LYMAN Rating Date: 04/09/1996

Address: PO BOX 815 Activity Status: Active

DELTA, UT 84624

Number of Units: 1

Phone Number: 435-864-2701

City Served (Area):

County: MILLARD COUNTY

Gal/Day Gal/Min

System Type: Non Transient Last Inv Update: 07/18/2011 Avg Daily Prod:
Activity Status Cd: Active Last Snty Srv Dt: 04/29/2008 Total Dsgn Cap:
Population: 70 Surveyor: ROGER FOISY Total Emerg Cap:

Oper Period: 1/1 to 12/31

**Contacts** 

Contact		Phone Numbers							
Type	Name	Title	Office	Emergency	Email Address				
AC	LYMAN, JEFFREY MASON		435-864-2707	435-846-2841	jmlyman@gmail.com				

#### Service Connections

Total Storage: 20,000 GAL

Connection Type	Meter Type Code	Meter Size	Number Connections	:
Industrial	Unknown	0	12	
			12 T	<ul> <li>total Svc Connections</li> </ul>

Adequate Capacity: NO

#### Storage

	-			-			
				Constr	Overflow	Activity	
No	Name	Type	Effective Volume	Matrl	Elev	Status	Press'd

No.	Name	Туре	Effective Volume	Matri	Elev	Status	Press'd
ST001	SMALL TANK	Ground	20,000 GAL	Plastic		Α	NO

### **Treatment Plants**

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Process
TP001	WELLS 1 AND 2 CHLORINATOR		Α	

## **Distribution System**

Pump Type	Total Dyn Hea ft H2O P.S	Pressure Adequate	Cross Connection	Auhority Statement
		No		

#### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1 (SOUTH)	Active	WL	12	1000 GPM	1,000 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2 (NORTH)	Active	WL	12	1000 GPM	1,000 GPM	Yes	GW	Permanent	1/1 to 12/31	

<sup>\*</sup>Reports measured flow for wells, approved design capacity for all other sources.